

ORDINANCE NO. 17-753

**AN ORDINANCE AMENDING A PORTION OF THE CITY OF
GENTRY'S ELECTRICAL CODE AS CODIFIED IN CHAPTER
11.12 OF THE CITY OF GENTRY MUNICIPAL CODE;
AND FOR OTHER PURPOSES.**

WHEREAS, the City of Gentry has previously adopted an Electrical Code which is codified in Chapter 11.12 of the City of Gentry Municipal Code; and

WHEREAS, it has come to the attention of the City of Gentry that there is need to amend the Gentry Electrical Code as hereinafter set forth.

NOW, therefore, be it ordained by the City Council of the City of Gentry, Arkansas;

- 1. Paragraph 11.12.10.B.11 of the Gentry Electrical Code is hereby deleted.**
- 2. Paragraph 11.12.10.B.11 of the Gentry Electrical Code shall instead provide:** Aluminum wire shall not be used for electrical service having a capacity rating of less than 100 amps.
- 3. Any provision of the Gentry Municipal Code in conflict with the provisions hereof is hereby deleted.**

PASSED and APPROVED this 6th day of February 2017.

Kevin D. Johnston, Mayor

Attest:

Tonya Carney, Director of Finance